

EU DECLARATION OF CONFORMITY

LK Armatur AB, Garnisonsgatan 49, SE - 254 66 Helsingborg – Sweden www.lkarmatur.se info@lkarmatur.se

DECLARES under its sole responsibility

the thermic safety valves

model 519 G3/4" x G3/4"

Nominal opening temperature 55°C, 85°C, 93°C, 97°C, 103°C with

sensor 1.3 m, 2.0 m and 4.0 m $\,$

COMPLY

with the Directive 2014/68/EU (PED) of 15 May 2014

CONFIRMS ALSO THAT

Category of the devices

IV

Conformity assessment procedure

В

The inspection was carried out by notified body "Consorzio Pascal" via Scarsellini, 11 - 20161 Milano – ITALY (identification number 1115)

The EU type examination – Production type 00054PED16001BP Rev 00 dated 2016.12.20.

Conformity assessment procedure

D

The inspection was carried out by notified body "ICIM S.p.A." Piazza Don Enrico Mapelli, 75, 20099 Sesto San Giovanni MI– ITALY (identification number 0425)

The EU type examination – the Production quality system approval certificate has protocol number PED 004186-00 dated 2020.11.18.

Helsingborg, 19 November 2020

Magnus Eriksson

Managing Director